

**Adani Electricity Mumbai Limited
Adani Dahanu Thermal Power Station**

Fuel Details for the month of Mar 2021 (As per Regulation 50.7 of MYT Regulations, 2019)

S No	Particulars	Units	Mar-21
1	Fuel parameters (for each primary and secondary fuel)		
1.1	Calorific Value (Received)		
1.1.1	Weighted Average GCV (Blended Coal as received)	Kcal/Kg	4135
1.1.2	Fuel 1 (Washed Coal)	Kcal/Kg	4141
1.1.3	Fuel 3 (Imported Coal)	Kcal/Kg	4065
1.1.4	Fuel 4 (LDO)	Kcal/Kg	10873
1.2	Calorific Value (fired)		
1.2.1	Weighted Average GCV (Blended Coal as Fired)	Kcal/Kg	4073
1.2.2	Fuel 1 (Washed Coal)	Kcal/Kg	4078
1.2.3	Fuel 3 (Imported Coal)	Kcal/Kg	4009
1.2.4	Fuel 4 (LDO)	Kcal/Kg	10873
1.3	Stacking Loss		
1.3.1	Weighted Average Stacking Loss	Kcal/Kg	62
1.3.2	Fuel 1 (Washed Coal)	Kcal/Kg	63
1.3.3	Fuel 3 (Imported Coal)	Kcal/Kg	56
1.3.4	Fuel 4 (LDO)	Kcal/Kg	0
1.4	Landed Fuel Price per unit		5605
1.4.1	Fuel 1 (Washed Coal)	Rs/MT	5594
1.4.2	Fuel 3 (Imported Coal)	Rs/MT	5737
1.4.3	Fuel 4 (LDO)	Rs/MT	43284
1.5	Blending Ratio	%	
1.5.1	Washed coal in primary fuel blend	%	92.18%
1.5.2	Imported coal in primary fuel blend	%	7.82%
1.5.3	LDO in secondary fuel basket	%	100.00%