

**Adani Electricity Mumbai Limited
Adani Dahanu Thermal Power Station**

Fuel Details for the month of December 2018 (As per Regulation 48.6 of MYT Regulations, 2015)

S. No.	Particulars	Units	Dec-18
1	Fuel parameters (for each primary and secondary fuel)		
1.1	Calorific Value (Received)		
1.1.1	Weighted Average GCV (Blended Coal as received)	kcal/Kg	3,942.78
1.1.2	Fuel 1 (Washed Coal)	kcal/Kg	3,911.00
1.1.3	Fuel 3 (Imported Coal)	kcal/Kg	4,082.00
1.1.4	Fuel 4 (LDO)	kcal/Kg	10,703.00
1.2	Calorific Value (fired)		
1.2.1	Weighted Average GCV (Blended Coal as fired)	kcal/Kg	3,856.13
1.2.2	Fuel 1 (Washed Coal)	kcal/Kg	3,808.00
1.2.3	Fuel 3 (Imported Coal)	kcal/Kg	4,067.00
1.2.4	Fuel 4 (LDO)	kcal/Kg	10,703.00
1.3	Stacking Loss		
1.3.1	Weighted Average Stacking Loss	kcal/Kg	86.65
1.3.2	Fuel 1 (Washed Coal)	kcal/Kg	103.00
1.3.3	Fuel 3 (Imported Coal)	kcal/Kg	15.00
1.3.4	Fuel 4 (LDO)	kcal/Kg	-
1.4	Landed Fuel Price per unit		
1.4.1	Fuel 1 (Washed Coal)	Rs./MT	5,298.36
1.4.2	Fuel 3 (Imported Coal)	Rs./MT	6,755.10
1.4.3	Fuel 4 (LDO)	Rs./MT	44,424.09
1.5	Blending Ratio		
1.5.1	Washed coal in primary fuel blend	%	81.42%
1.5.2	Imported coal in primary fuel blend	%	18.58%
1.5.3	LDO in secondary fuel basket	%	100.00%