

**Adani Electricity Mumbai Limited
Adani Dahanu Thermal Power Station**

Fuel Details for the month of March 2019 (As per Regulation 48.6 of MYT Regulations, 2015)

S. No.	Particulars	Units	Mar-19
1	Fuel parameters (for each primary and secondary fuel)		
1.1	Calorific Value (Received)		
1.1.1	Weighted Average GCV (Blended Coal as received)	kcal/Kg	3,993.44
1.1.2	Fuel 1 (Washed Coal)	kcal/Kg	3,999.00
1.1.3	Fuel 3 (Imported Coal)	kcal/Kg	3,973.00
1.1.4	Fuel 4 (LDO)	kcal/Kg	10,721.00
1.2	Calorific Value (fired)		
1.2.1	Weighted Average GCV (Blended Coal as fired)	kcal/Kg	3,896.93
1.2.2	Fuel 1 (Washed Coal)	kcal/Kg	3,898.00
1.2.3	Fuel 3 (Imported Coal)	kcal/Kg	3,893.00
1.2.4	Fuel 4 (LDO)	kcal/Kg	10,721.00
1.3	Stacking Loss		
1.3.1	Weighted Average Stacking Loss	kcal/Kg	96.51
1.3.2	Fuel 1 (Washed Coal)	kcal/Kg	101.00
1.3.3	Fuel 3 (Imported Coal)	kcal/Kg	80.00
1.3.4	Fuel 4 (LDO)	kcal/Kg	-
1.4	Landed Fuel Price per unit		
1.4.1	Fuel 1 (Washed Coal)	Rs./MT	5,320.31
1.4.2	Fuel 3 (Imported Coal)	Rs./MT	5,942.69
1.4.3	Fuel 4 (LDO)	Rs./MT	46,317.17
1.5	Blending Ratio		
1.5.1	Washed coal in primary fuel blend	%	78.61%
1.5.2	Imported coal in primary fuel blend	%	21.39%
1.5.3	LDO in secondary fuel basket	%	100.00%