

**Annexure-I**  
**Standards of Performance Level by the Distribution Licensee**  
**Format for Quarterly Return to be submitted to the Commission by the Distribution Licensee**

Name of Distribution Licensee: Adani Electricity Mumbai Limited  
Period: July 2018 to Sept-2018

Sr.No.	SOP Regulation No.	Parameters	Area	Pending complaint Nos. (previous Quarter)	Complaints in current Qtr.	Total complaints	No. of complaints addressed			Pending complaints at end of Qtr.	Remarks
							Within Standards of performance	More than stipulated time	Total complaints redressed		
	a	b	c	d	e	f=d+e	g	h	i=g+h	j=f-i	
1	4.3	New connection* - inspection of premises	Class-I Cities/Urban	61	7114	7175	7172	1	7173	2	Delayed due to Non Compliance by applicant -1 case
2	4.4	Intimation of charges where supply from existing lines	Class-I Cities/Urban	82	5418	5500	5493	1	5494	6	Delayed due to Non Compliance by applicant -1 case
3	4.5 & 4.6	Intimation of charges where supply to dedicated or after extension / augmentation	Class-I Cities/Urban	44	1696	1740	1726	1	1727	13	Delayed due to Wrong application by applicant-1 case
4	4.7	New connection/ add. load where supply from existing line		203	5392	5595	5201	81	5282	313	Delayed due to - Non-Compliance by applicant-72 cases, Third party Objection -9 cases
5	4.8	New connection/ add. Load where supply after		312	1596	1908	1457	0	1457	451	
6	4.9	New connection/ add. load where supply after		0	0	0	0	0	0	0	
7	4.12	Shifting of Meter / service Line	Class-I Cities/Urban	416	409	825	420	0	420	405	
8	6.10	Reconnection of supply after payment of dues	Class-I Cities/Urban	0	14019	14019	14019	0	14019	0	
9	4.13	Change of Name		0	18941	18941	18941	0	18941	0	
10	4.13	Change of category		142	1054	1196	1056	0	1056	140	
11	5.4 (a)	Complaint of Voltage		0	1150	1150	1150	0	1150	0	
12	5.4 (b)	Complaint of Voltage		0	702	702	702	0	702	0	
13	5.4 (c)	Complaint of Voltage Variation - Expansion /		0	0	0	0	0	0	0	
14	6.1	Fuse off call	Class-I Cities/Urban	0	22566	22566	22386	180	22566	0	Refer Notes below
15	6.2	Breakdown of Overhead Line	Class-I Cities/Urban	0	1	1	1	0	1	0	

Sr.No.	SOP Regulation No.	Parameters	Area	Pending complaint Nos. (previous Quarter)	Complaints in current Qtr.	Total complaints	No. of complaints addressed			Pending complaints at end of Qtr.	Remarks
							Within Standards of performance	More than stipulated time	Total complaints redressed		
16	6.3	Underground Cable fault	Class-I Cities/Urban	0	15969	15969	14981	988	15969	0	Refer Notes below
17	6.4	Transformer failure	Class-I Cities/Urban	0	6	6	6	0	6	0	
18	7.2	Meter Reading		0	7351925	7351925	7350956	969	7351925	0	Delayed due to - No access to meter cabin : 538, Key not available : 431
19	7.3	Replacement of Faulty Meter**	Class-I Cities/Urban	0	2931	2931	2931	0	2931	0	
20	7.4	Replacement of Burnt Meter	Class-I Cities/Urban	0	1902	1902	1902	0	1902	0	
21	7.6 , 7.7	Billing Complaint		133	7824	7957	7261	0	7261	696	

Notes:

\* New Connection report is based on number of applications received of individual building wherein multiple meters are connected.

\*\* Faulty meter includes- Defect in the meters not affecting the customer's supply, however affecting recording of consumer's consumption and needs immediate replacement. This does not include black spot meters, meters used for reconnection of supply, meter replaced on consumer request, stolen or missing meters.

**Fuse of Call & Underground Cable faults:**

Sr.no	Reasons for delay	6.1 Fuse off call	6.3UG Cable fault
1	In theft prone areas miscreants are tapping wires from AEML's feeder boxes and meter cabins. The overloading due to such unauthorized load results in to interruption of supply. AEML is taking efforts to remove such unauthorized connections from time to time. During any interruption, for safety purpose, AEML needs to first remove such unauthorized connections and then restore the supply. This results in delay in restoration of supply to complainant or even delay repairing of fault. Events related to this reason are specified here.	16	311
2	Adverse site conditions (cable deep/multiple cables at one location/road crossing/supply restoration not possible by temporary means/mass objection): AEML's network is developed over 7 decades. Due to road widening, level raising, concerting, etc. cables have gone deep under the roads. It takes time to get all necessary permission and excavation for repair of such faults. Since using temporary cable or wire on such public roads is safety hazard, it is preferred to repair the fault. Mass objections on site is also faced sometimes. Availability of multiple Utilities under ground and makes it difficult to trace/locate the fault. In such cases supply restoration is delayed.	31	189
3	Heavy Rains, Water Logging, water ingress due to side by Nalla: In such conditions it becomes difficult to access installation/cables. In such cases it take more time to attended compliant/fault.	17	130
4	Request from Consumer to attend the fault at later suitable time	0	98
5	Fault at Consumer installation, which consumer needs to rectify. Supply is kept OFF for safety purpose.	0	28
6	Objection from Consumer: Some time consumers in the area take the objection (specially in slums) for excavation or laying of temporary cable or wire. At times it becomes very difficult to convince public and take longer time. Such events are covered here.	0	20
7	Access issue to meter cabin /AEML network equipment: Many times it is found that the access to AEML feeder pillars / meter cabin is blocked due to car or motor cycle parking or by any other means. This requires first removal of such obstructions to get access. It take linger time to search owner or call traffic police to get the site cleared. Once the access is available, repairing work is initiated. However, this delays the supply restoration.	0	15
8	Labour commotion	116	192
9	Multiple Faults: In some cases multiple faults get developed due to damages by external agency (e.g. road widening/concreting contractors). After repair of one fault, on testing other fault is noticed. Restoration is not possible unless all the faults are repaired.	0	1
10	Multiple services tapped from common point/main network: It was old practice to tap services from common point. If any service cable becomes faulty, for isolation, it takes more time as all services need to be removed, diverted and then take-up the work on faulty service. In such cases it requires more time as number of works involved are multiple	0	4
<b>Grand Total</b>		<b>180</b>	<b>988</b>

**Annexure-II**  
**Report of individual Complaints where Compensation has been paid**  
**Format for quarterly return to be submitted to the Commission by the Distribution Licensee**

Name of Distribution Licensee: Adani Electricity Mumbai Limited  
Period: July 2018 to Sept-2018

Sr. No.	Complaint No.	Date of filing complaint	Consumer No.	Name and address of Consumer	Nature of Complaint	Reference Standard of Performance	Amount of Compensation (Rs.)	Date of payment of Compensation (DD/MM/YYYY)
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	NIL							
2								
3								
4								
5								
6								
7								

**NOTE -** The report shall be prepared as per category of item for which the compensation is paid for non- observance of Standards of Performance.

**Annexure-III**  
**Report of action on Faulty Meters (1 Phase/ 3 Phase)**  
**Format for quarterly return to be submitted to the Commission by the Distribution Licensee**

**Name of Distribution Licensee: Adani Electricity Mumbai Limited**  
**Period: July 2018 to Sept-2018**

Sr.No.	Name of Distribution Licensee	Reference to Overall Standards	Faulty Meters at the start of the Quarter (Nos.)	Faulty Meters added during Quarter (Nos.)	Total Faulty Meters (Nos.)	Meters rectified / replaced (Nos.)	Faulty Meters pending at end of Quarter (Nos.)
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)
1	AEML	7.3	0	2931	2931	2931	0
2							
3							
4							
5							

Note:

Faulty meter includes- Defect in the meters not affecting the customer's supply, however affecting recording of consumer's consumption and needs immediate replacement. This does not include black spot meters, meters used for reconnection of supply, meter replaced on consumer request, stolen or missing meters.

**Annexure-IV**  
**Performance Report regarding Reliability Indices**

**Formats for Quarterly returns to be submitted to the Commission by the Distribution Licensee**  
**(1) System Average Interruption Duration Index (SAIDI)**

**Name of Distribution Licensee: Adani Electricity Mumbai Limited**

**Period: July 2018 to Sept-2018**

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Ri = Restoration time for each interruption event on ith feeder	Nt = Total number of consumers of the distribution Licensees area	Sum(Ri*Ni) for all feeders (excluding agri. Feeders)	SAIDI = (6)/(5)(In minutes)
(1)	(2)	(3)	(4)	(5)	(6)	(7)
1	Jul-18	1	21	3013966	21	0.0000
2	Jul-18	36	20	3013966	720	0.0002
3	Jul-18	172	6.2	3013966	1066	0.0004
4	Jul-18	163	10	3013966	1630	0.0005
5	Jul-18	257	13.5	3013966	3470	0.0012
6	Jul-18	211	20	3013966	4220	0.0014
7	Jul-18	290	18	3013966	5220	0.0017
8	Jul-18	392	15	3013966	5880	0.0020
9	Jul-18	257	32.74	3013966	8414	0.0028
10	Jul-18	425	21	3013966	8925	0.0030
11	Jul-18	374	23.87	3013966	8927	0.0030
12	Jul-18	392	28.44	3013966	11148	0.0037
13	Jul-18	902	17	3013966	15334	0.0051
14	Jul-18	1523	10.27	3013966	15641	0.0052
15	Jul-18	594	28.03	3013966	16650	0.0055
16	Jul-18	1047	17.32	3013966	18134	0.0060
17	Jul-18	446	41.69	3013966	18594	0.0062
18	Jul-18	1312	15.93	3013966	20900	0.0069
19	Jul-18	1064	20	3013966	21280	0.0071
20	Jul-18	1291	16.7	3013966	21560	0.0072
21	Jul-18	1037	21.22	3013966	22005	0.0073
22	Jul-18	3700	6	3013966	22200	0.0074
23	Jul-18	1316	18	3013966	23688	0.0079
24	Jul-18	2863	8.8	3013966	25194	0.0084
25	Jul-18	1263	20	3013966	25260	0.0084
26	Jul-18	585	43.29	3013966	25325	0.0084
27	Jul-18	1438	18.27	3013966	26272	0.0087
28	Jul-18	761	37	3013966	28157	0.0093
29	Jul-18	1261	22.42	3013966	28272	0.0094
30	Jul-18	863	33	3013966	28479	0.0094
31	Jul-18	1203	24	3013966	28872	0.0096
32	Jul-18	771	39.02	3013966	30084	0.0100
33	Jul-18	1678	19.3	3013966	32385	0.0107
34	Jul-18	804	40.99	3013966	32956	0.0109
35	Jul-18	2050	16.77	3013966	34379	0.0114
36	Jul-18	1380	25.88	3013966	35714	0.0118

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Ri = Restoration time for each interruption event on ith feeder	Nt = Total number of consumers of the distribution Licensees area	Sum(Ri*Ni) for all feeders (excluding agri. Feeders)	SAIDI = (6)/(5)(In minutes)
37	Jul-18	2221	20	3013966	44420	0.0147
38	Jul-18	2076	21.62	3013966	44883	0.0149
39	Jul-18	2169	22	3013966	47718	0.0158
40	Jul-18	1384	34.87	3013966	48260	0.0160
41	Jul-18	1497	35.06	3013966	52485	0.0174
42	Jul-18	3077	18.06	3013966	55571	0.0184
43	Jul-18	1767	35.3	3013966	62375	0.0207
44	Jul-18	2944	22	3013966	64768	0.0215
45	Jul-18	1993	34.05	3013966	67862	0.0225
46	Jul-18	2985	23.75	3013966	70894	0.0235
47	Jul-18	2135	36.09	3013966	77052	0.0256
48	Jul-18	5375	18.4	3013966	98900	0.0328
49	Jul-18	3263	34.89	3013966	113846	0.0378
50	Jul-18	5375	21.26	3013966	114273	0.0379
51	Jul-18	5609	21.39	3013966	119977	0.0398
52	Jul-18	5033	26.16	3013966	131663	0.0437
53	Jul-18	1897	74.8	3013966	141896	0.0471
54	Jul-18	5997	25.05	3013966	150225	0.0498
55	Jul-18	5177	29.7	3013966	153757	0.0510
56	Jul-18	3818	41.41	3013966	158103	0.0525
57	Jul-18	4091	39	3013966	159549	0.0529
58	Jul-18	4527	42.21	3013966	191085	0.0634
59	Jul-18	6124	38.43	3013966	235345	0.0781
60	Jul-18	8290	31	3013966	256990	0.0853
61	Jul-18	7780	39.93	3013966	310655	0.1031
62	Jul-18	23213	25.12	3013966	583111	0.1935
63	Jul-18	88	18	3013966	1584	0.0005
64	Jul-18	35	52.42	3013966	1835	0.0006
65	Jul-18	418	59.51	3013966	24875	0.0083
66	Jul-18	1461	18.62	3013966	27204	0.0090
67	Jul-18	2771	12.69	3013966	35164	0.0117
68	Jul-18	1093	40.65	3013966	44430	0.0147
69	Jul-18	489	103.2	3013966	50465	0.0167
70	Jul-18	1202	61.91	3013966	74416	0.0247
71	Jul-18	6408	24.16	3013966	154817	0.0514
72	Jul-18	4508	34.36	3013966	154895	0.0514
73	Jul-18	2910	76.31	3013966	222062	0.0737
74	Jul-18	1530	24.24	3013966	37087	0.0123
75	Jul-18	6189	10.28	3013966	63623	0.0211
76	Jul-18	4687	35.07	3013966	164373	0.0545
77	Jul-18	4572	49	3013966	224028	0.0743
78	Jul-18	290	29	3013966	8410	0.0028
79	Jul-18	2794	7	3013966	19558	0.0065
80	Jul-18	1756	25.77	3013966	45252	0.0150
81	Jul-18	5109	9	3013966	45981	0.0153
82	Jul-18	4586	24	3013966	110064	0.0365
83	Jul-18	9733	14.18	3013966	138014	0.0458
Total		216568	27.06	3013966	5860776	1.9445

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Ri = Restoration time for each interruption event on ith feeder	Nt = Total number of consumers of the distribution Licensees area	Sum(Ri*Ni) for all feeders (excluding agri. Feeders)	SAIDI = (6)/(5)(In minutes)
--------	-------	---	---	---	--	-----------------------------

Remark :

- 1 Customer served by Rinfra are 3013966 nos.
- 2 Number of feeders are 1164 Nos.



**Annexure-IV**  
**Performance Report regarding Reliability Indices**

Formats for Quarterly returns to be submitted to the Commission by the Distribution Licensee

(1) System Average Interruption Duration Index (SAIDI)

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Ri = Restoration time for each interruption event on ith feeder	Nt = Total number of consumers of the distribution Licensees area	Sum(Ri*Ni) for all feeders (excluding agri. Feeders)	SAIDI = (6)/(5)(In minutes)
(1)	(2)	(3)	(4)	(5)	(6)	(7)
1	Aug-18	70	15.4	3015065	1078	0.0004
2	Aug-18	260	14.88	3015065	3869	0.0013
3	Aug-18	177	22	3015065	3894	0.0013
4	Aug-18	229	36.53	3015065	8365	0.0028
5	Aug-18	586	18	3015065	10548	0.0035
6	Aug-18	471	27.01	3015065	12722	0.0042
7	Aug-18	1274	13.03	3015065	16600	0.0055
8	Aug-18	876	20	3015065	17520	0.0058
9	Aug-18	2171	13	3015065	28223	0.0094
10	Aug-18	1901	15.92	3015065	30264	0.0100
11	Aug-18	765	43.25	3015065	33086	0.0110
12	Aug-18	2228	16.18	3015065	36049	0.0120
13	Aug-18	1655	27	3015065	44685	0.0148
14	Aug-18	2191	23	3015065	50393	0.0167
15	Aug-18	1818	29.5	3015065	53631	0.0178
16	Aug-18	2362	22.95	3015065	54208	0.0180
17	Aug-18	1091	50.14	3015065	54703	0.0181
18	Aug-18	2394	23	3015065	55062	0.0183
19	Aug-18	2191	28	3015065	61348	0.0203
20	Aug-18	6089	11	3015065	66979	0.0222
21	Aug-18	2862	23.83	3015065	68201	0.0226
22	Aug-18	1979	35	3015065	69265	0.0230
23	Aug-18	4207	18	3015065	75726	0.0251
24	Aug-18	2191	35	3015065	76685	0.0254
25	Aug-18	2718	34	3015065	92412	0.0307
26	Aug-18	2544	36.66	3015065	93263	0.0309
27	Aug-18	3634	27.22	3015065	98917	0.0328
28	Aug-18	3050	37.48	3015065	114314	0.0379
29	Aug-18	4028	29.29	3015065	117980	0.0391
30	Aug-18	8129	16.62	3015065	135104	0.0448
31	Aug-18	31037	6	3015065	186222	0.0618
32	Aug-18	6420	40.51	3015065	260074	0.0863
33	Aug-18	2222	146	3015065	324412	0.1076
34	Aug-18	11832	30.3	3015065	358510	0.1189
35	Aug-18	7331	76.78	3015065	562874	0.1867
36	Aug-18	24	231	3015065	5544	0.0018

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Ri = Restoration time for each interruption event on ith feeder	Nt = Total number of consumers of the distribution Licensees area	Sum(Ri*Ni) for all feeders (excluding agri. Feeders)	SAIDI = (6)/(5)(In minutes)
37	Aug-18	1416	46.85	3015065	66340	0.0220
38	Aug-18	4290	16.32	3015065	70013	0.0232
39	Aug-18	5452	28.8	3015065	157018	0.0521
40	Aug-18	3019	55.27	3015065	166860	0.0553
41	Aug-18	2538	76.38	3015065	193852	0.0643
42	Aug-18	4	46.8	3015065	187	0.0001
43	Aug-18	781	23.56	3015065	18400	0.0061
44	Aug-18	7799	30.58	3015065	238493	0.0791
45	Aug-18	480	7	3015065	3360	0.0011
46	Aug-18	536	10	3015065	5360	0.0018
47	Aug-18	536	18	3015065	9648	0.0032
48	Aug-18	1598	10	3015065	15980	0.0053
49	Aug-18	2168	8	3015065	17344	0.0058
50	Aug-18	2544	9	3015065	22896	0.0076
51	Aug-18	2862	17.15	3015065	49083	0.0163
Total		161030	26.81	3015065	4317566	1.4320

Remark :

- 1 Customer served by Rinfra are 3015065 nos.
- 2 Number of feeders are 1167 Nos.

**Annexure-IV**  
**Performance Report regarding Reliability Indices**

**Formats for Quarterly returns to be submitted to the Commission by the Distribution Licensee**  
**(1) System Average Interruption Duration Index (SAIDI)**

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Ri = Restoration time for each interruption event on ith feeder	Nt = Total number of consumers of the distribution Licensees area	Sum(Ri*Ni) for all feeders (excluding agri. Feeders)	SAIDI = (6)/(5)(In minutes)
(1)	(2)	(3)	(4)	(5)	(6)	(7)
1	Sep-18	1	24	3014468	24	0.0000
2	Sep-18	4	30.45	3014468	122	0.0000
3	Sep-18	22	24.22	3014468	533	0.0002
4	Sep-18	18	34	3014468	612	0.0002
5	Sep-18	32	24	3014468	768	0.0003
6	Sep-18	343	7.87	3014468	2699	0.0009
7	Sep-18	257	21	3014468	5397	0.0018
8	Sep-18	276	20	3014468	5520	0.0018
9	Sep-18	536	15	3014468	8040	0.0027
10	Sep-18	727	15	3014468	10905	0.0036
11	Sep-18	353	32	3014468	11296	0.0037
12	Sep-18	672	17.04	3014468	11451	0.0038
13	Sep-18	576	21.88	3014468	12603	0.0042
14	Sep-18	667	19	3014468	12673	0.0042
15	Sep-18	661	21	3014468	13881	0.0046
16	Sep-18	729	20	3014468	14580	0.0048
17	Sep-18	672	22	3014468	14784	0.0049
18	Sep-18	1137	13.55	3014468	15406	0.0051
19	Sep-18	921	20	3014468	18420	0.0061
20	Sep-18	974	19.87	3014468	19353	0.0064
21	Sep-18	1140	19	3014468	21660	0.0072
22	Sep-18	2218	9.86	3014468	21869	0.0073
23	Sep-18	1088	20.34	3014468	22130	0.0073
24	Sep-18	672	33	3014468	22176	0.0074
25	Sep-18	1678	15	3014468	25170	0.0083
26	Sep-18	2204	11.45	3014468	25236	0.0084
27	Sep-18	1769	15.3	3014468	27066	0.0090
28	Sep-18	991	30.44	3014468	30166	0.0100
29	Sep-18	1539	21.92	3014468	33735	0.0112
30	Sep-18	588	58.98	3014468	34680	0.0115
31	Sep-18	5943	6	3014468	35658	0.0118
32	Sep-18	2260	16	3014468	36160	0.0120
33	Sep-18	2693	15.94	3014468	42926	0.0142
34	Sep-18	1497	28.91	3014468	43278	0.0144
35	Sep-18	3433	13	3014468	44629	0.0148
36	Sep-18	1871	27.56	3014468	51565	0.0171

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Ri = Restoration time for each interruption event on ith feeder	Nt = Total number of consumers of the distribution Licensees area	Sum(Ri*Ni) for all feeders (excluding agri. Feeders)	SAIDI = (6)/(5)(In minutes)
37	Sep-18	2823	18.64	3014468	52621	0.0175
38	Sep-18	1633	32.24	3014468	52648	0.0175
39	Sep-18	3433	17	3014468	58361	0.0194
40	Sep-18	1843	35.01	3014468	64523	0.0214
41	Sep-18	4227	17.02	3014468	71944	0.0239
42	Sep-18	5294	13.66	3014468	72316	0.0240
43	Sep-18	1402	56.78	3014468	79606	0.0264
44	Sep-18	2345	36.02	3014468	84467	0.0280
45	Sep-18	1818	51	3014468	92718	0.0308
46	Sep-18	5151	18	3014468	92718	0.0308
47	Sep-18	4862	20.09	3014468	97678	0.0324
48	Sep-18	1457	68.84	3014468	100300	0.0333
49	Sep-18	4952	20.31	3014468	100575	0.0334
50	Sep-18	3007	35.59	3014468	107019	0.0355
51	Sep-18	2393	47.17	3014468	112878	0.0374
52	Sep-18	3293	37.34	3014468	122961	0.0408
53	Sep-18	6193	21.22	3014468	131415	0.0436
54	Sep-18	7508	19.72	3014468	148058	0.0491
55	Sep-18	3940	41	3014468	161540	0.0536
56	Sep-18	5451	30.01	3014468	163585	0.0543
57	Sep-18	8262	19.87	3014468	164166	0.0545
58	Sep-18	5375	34.13	3014468	183449	0.0609
59	Sep-18	6935	26.96	3014468	186968	0.0620
60	Sep-18	5084	38.31	3014468	194768	0.0646
61	Sep-18	4613	43.98	3014468	202880	0.0673
62	Sep-18	8445	24.96	3014468	210787	0.0699
63	Sep-18	6047	37.03	3014468	223920	0.0743
64	Sep-18	1245	552.18	3014468	687464	0.2281
65	Sep-18	3548	249.52	3014468	885297	0.2937
66	Sep-18	3	53	3014468	159	0.0001
67	Sep-18	357	13	3014468	4641	0.0015
68	Sep-18	1456	14.33	3014468	20864	0.0069
69	Sep-18	1540	33.99	3014468	52345	0.0174
70	Sep-18	4171	13.1	3014468	54640	0.0181
71	Sep-18	1675	36.65	3014468	61389	0.0204
72	Sep-18	2614	32	3014468	83648	0.0277
73	Sep-18	4971	17.53	3014468	87142	0.0289
74	Sep-18	403	235.2	3014468	94786	0.0314
75	Sep-18	4047	39.28	3014468	158966	0.0527
76	Sep-18	1013	202	3014468	204626	0.0679
77	Sep-18	1169	557	3014468	651133	0.2160
78	Sep-18	26	6.62	3014468	172	0.0001
79	Sep-18	29	18	3014468	522	0.0002
80	Sep-18	524	35	3014468	18340	0.0061
81	Sep-18	990	27.33	3014468	27057	0.0090
82	Sep-18	1897	18	3014468	34146	0.0113
83	Sep-18	3907	39.23	3014468	153272	0.0508
84	Sep-18	4862	36.14	3014468	175713	0.0583

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Ri = Restoration time for each interruption event on ith feeder	Nt = Total number of consumers of the distribution Licensees area	Sum(Ri*Ni) for all feeders (excluding agri. Feeders)	SAIDI = (6)/(5)(In minutes)
85	Sep-18	1	10.8	3014468	11	0.0000
86	Sep-18	5696	109.35	3014468	622858	0.2066
Total		205092	39.55	3014468	8111228	2.6908

Remark :

- 1 Customer served by Rinfra are 3014468 nos.
- 2 Number of feeders are 1167 Nos.

**Annexure-IV**  
**Performance Report regarding Reliability Indices**

**Formats for Quarterly returns to be submitted to the Commission by the Distribution Licensee**  
**(2) System Average Interruption Frequency Index (SAIFI)**

**Name of Distribution Licensee: Adani Electricity Mumbai Limited**  
**Period: July 2018 to Sept-2018**

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Sum of consumers of i feeders which had experienced interruptions = Sum Ni	Nt = Total number of consumers of the distribution Licensees area	SAIFI = (4) / (5) (Events)
(1)	(2)	(3)	(4)	(5)	(6)
1	Jul-18	1	1	3013966	0.0000
2	Jul-18	36	36	3013966	0.0000
3	Jul-18	172	172	3013966	0.0001
4	Jul-18	163	163	3013966	0.0001
5	Jul-18	257	257	3013966	0.0001
6	Jul-18	211	211	3013966	0.0001
7	Jul-18	290	290	3013966	0.0001
8	Jul-18	392	392	3013966	0.0001
9	Jul-18	257	257	3013966	0.0001
10	Jul-18	425	425	3013966	0.0001
11	Jul-18	374	374	3013966	0.0001
12	Jul-18	392	392	3013966	0.0001
13	Jul-18	902	902	3013966	0.0003
14	Jul-18	1523	1523	3013966	0.0005
15	Jul-18	594	594	3013966	0.0002
16	Jul-18	1047	1047	3013966	0.0003
17	Jul-18	446	446	3013966	0.0001
18	Jul-18	1312	1312	3013966	0.0004
19	Jul-18	1064	1064	3013966	0.0004
20	Jul-18	1291	1291	3013966	0.0004
21	Jul-18	1037	1037	3013966	0.0003
22	Jul-18	3700	3700	3013966	0.0012
23	Jul-18	1316	1316	3013966	0.0004
24	Jul-18	2863	2863	3013966	0.0009
25	Jul-18	1263	1263	3013966	0.0004
26	Jul-18	585	585	3013966	0.0002
27	Jul-18	1438	1438	3013966	0.0005
28	Jul-18	761	761	3013966	0.0003
29	Jul-18	1261	1261	3013966	0.0004
30	Jul-18	863	863	3013966	0.0003
31	Jul-18	1203	1203	3013966	0.0004
32	Jul-18	771	771	3013966	0.0003
33	Jul-18	1678	1678	3013966	0.0006
34	Jul-18	804	804	3013966	0.0003
35	Jul-18	2050	2050	3013966	0.0007
36	Jul-18	1380	1380	3013966	0.0005
37	Jul-18	2221	2221	3013966	0.0007
38	Jul-18	2076	2076	3013966	0.0007
39	Jul-18	2169	2169	3013966	0.0007
40	Jul-18	1384	1384	3013966	0.0005
41	Jul-18	1497	1497	3013966	0.0005
42	Jul-18	3077	3077	3013966	0.0010
43	Jul-18	1767	1767	3013966	0.0006
44	Jul-18	2944	2944	3013966	0.0010

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Sum of consumers of i feeders which had experienced interruptions = Sum Ni	Nt = Total number of consumers of the distribution Licensees area	SAIFI = (4) / (5) (Events)
45	Jul-18	1993	1993	3013966	0.0007
46	Jul-18	2985	2985	3013966	0.0010
47	Jul-18	2135	2135	3013966	0.0007
48	Jul-18	5375	5375	3013966	0.0018
49	Jul-18	3263	3263	3013966	0.0011
50	Jul-18	5375	5375	3013966	0.0018
51	Jul-18	5609	5609	3013966	0.0019
52	Jul-18	5033	5033	3013966	0.0017
53	Jul-18	1897	1897	3013966	0.0006
54	Jul-18	5997	5997	3013966	0.0020
55	Jul-18	5177	5177	3013966	0.0017
56	Jul-18	3818	3818	3013966	0.0013
57	Jul-18	4091	4091	3013966	0.0014
58	Jul-18	4527	4527	3013966	0.0015
59	Jul-18	6124	6124	3013966	0.0020
60	Jul-18	8290	8290	3013966	0.0028
61	Jul-18	7780	7780	3013966	0.0026
62	Jul-18	23213	23213	3013966	0.0077
63	Jul-18	88	88	3013966	0.0000
64	Jul-18	35	35	3013966	0.0000
65	Jul-18	418	418	3013966	0.0001
66	Jul-18	1461	1461	3013966	0.0005
67	Jul-18	2771	2771	3013966	0.0009
68	Jul-18	1093	1093	3013966	0.0004
69	Jul-18	489	489	3013966	0.0002
70	Jul-18	1202	1202	3013966	0.0004
71	Jul-18	6408	6408	3013966	0.0021
72	Jul-18	4508	4508	3013966	0.0015
73	Jul-18	2910	2910	3013966	0.0010
74	Jul-18	1530	1530	3013966	0.0005
75	Jul-18	6189	6189	3013966	0.0021
76	Jul-18	4687	4687	3013966	0.0016
77	Jul-18	4572	4572	3013966	0.0015
78	Jul-18	290	290	3013966	0.0001
79	Jul-18	2794	2794	3013966	0.0009
80	Jul-18	1756	1756	3013966	0.0006
81	Jul-18	5109	5109	3013966	0.0017
82	Jul-18	4586	4586	3013966	0.0015
83	Jul-18	9733	9733	3013966	0.0032
Total		216568	216568	3013966	0.0719

Remark :

- 1 Customer served by Rinfra are 3013966 nos.
- 2 Number of feeders are 1164 Nos.

**Annexure-IV**  
**Performance Report regarding Reliability Indices**

**Formats for Quarterly returns to be submitted to the Commission by the Distribution Licensee**  
**(2) System Average Interruption Frequency Index (SAIFI)**

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Sum of consumers of i feeders which had experienced interruptions = Sum Ni	Nt = Total number of consumers of the distribution Licensees area	SAIFI = (4) / (5) (Events)
(1)	(2)	(3)	(4)	(5)	(6)
1	Aug-18	70	70	3015065	0.0000
2	Aug-18	260	260	3015065	0.0001
3	Aug-18	177	177	3015065	0.0001
4	Aug-18	229	229	3015065	0.0001
5	Aug-18	586	586	3015065	0.0002
6	Aug-18	471	471	3015065	0.0002
7	Aug-18	1274	1274	3015065	0.0004
8	Aug-18	876	876	3015065	0.0003
9	Aug-18	2171	2171	3015065	0.0007
10	Aug-18	1901	1901	3015065	0.0006
11	Aug-18	765	765	3015065	0.0003
12	Aug-18	2228	2228	3015065	0.0007
13	Aug-18	1655	1655	3015065	0.0005
14	Aug-18	2191	2191	3015065	0.0007
15	Aug-18	1818	1818	3015065	0.0006
16	Aug-18	2362	2362	3015065	0.0008
17	Aug-18	1091	1091	3015065	0.0004
18	Aug-18	2394	2394	3015065	0.0008
19	Aug-18	2191	2191	3015065	0.0007
20	Aug-18	6089	6089	3015065	0.0020
21	Aug-18	2862	2862	3015065	0.0009
22	Aug-18	1979	1979	3015065	0.0007
23	Aug-18	4207	4207	3015065	0.0014
24	Aug-18	2191	2191	3015065	0.0007
25	Aug-18	2718	2718	3015065	0.0009
26	Aug-18	2544	2544	3015065	0.0008
27	Aug-18	3634	3634	3015065	0.0012
28	Aug-18	3050	3050	3015065	0.0010
29	Aug-18	4028	4028	3015065	0.0013
30	Aug-18	8129	8129	3015065	0.0027
31	Aug-18	31037	31037	3015065	0.0103
32	Aug-18	6420	6420	3015065	0.0021
33	Aug-18	2222	2222	3015065	0.0007
34	Aug-18	11832	11832	3015065	0.0039
35	Aug-18	7331	7331	3015065	0.0024
36	Aug-18	24	24	3015065	0.0000
37	Aug-18	1416	1416	3015065	0.0005
38	Aug-18	4290	4290	3015065	0.0014
39	Aug-18	5452	5452	3015065	0.0018
40	Aug-18	3019	3019	3015065	0.0010
41	Aug-18	2538	2538	3015065	0.0008
42	Aug-18	4	4	3015065	0.0000
43	Aug-18	781	781	3015065	0.0003
44	Aug-18	7799	7799	3015065	0.0026



Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Sum of consumers of i feeders which had experienced interruptions = Sum Ni	Nt = Total number of consumers of the distribution Licensees area	SAIFI = (4) / (5) (Events)
45	Aug-18	480	480	3015065	0.0002
46	Aug-18	536	536	3015065	0.0002
47	Aug-18	536	536	3015065	0.0002
48	Aug-18	1598	1598	3015065	0.0005
49	Aug-18	2168	2168	3015065	0.0007
50	Aug-18	2544	2544	3015065	0.0008
51	Aug-18	2862	2862	3015065	0.0009
Total		161030	161030	3015065	0.0534

Remark :

- 1 Customer served by Rinfra are 3015065 nos.
- 2 Number of feeders are 1167 Nos.

**Annexure-IV**  
**Performance Report regarding Reliability Indices**

**Formats for Quarterly returns to be submitted to the Commission by the Distribution Licensee**  
**(2) System Average Interruption Frequency Index (SAIFI)**

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Sum of consumers of i feeders which had experienced interruptions = Sum Ni	Nt = Total number of consumers of the distribution Licensees area	SAIFI = (4) / (5) (Events)
(1)	(2)	(3)	(4)	(5)	(6)
1	Sep-18	1	1	3014468	0.0000
2	Sep-18	4	4	3014468	0.0000
3	Sep-18	22	22	3014468	0.0000
4	Sep-18	18	18	3014468	0.0000
5	Sep-18	32	32	3014468	0.0000
6	Sep-18	343	343	3014468	0.0001
7	Sep-18	257	257	3014468	0.0001
8	Sep-18	276	276	3014468	0.0001
9	Sep-18	536	536	3014468	0.0002
10	Sep-18	727	727	3014468	0.0002
11	Sep-18	353	353	3014468	0.0001
12	Sep-18	672	672	3014468	0.0002
13	Sep-18	576	576	3014468	0.0002
14	Sep-18	667	667	3014468	0.0002
15	Sep-18	661	661	3014468	0.0002
16	Sep-18	729	729	3014468	0.0002
17	Sep-18	672	672	3014468	0.0002
18	Sep-18	1137	1137	3014468	0.0004
19	Sep-18	921	921	3014468	0.0003
20	Sep-18	974	974	3014468	0.0003
21	Sep-18	1140	1140	3014468	0.0004
22	Sep-18	2218	2218	3014468	0.0007
23	Sep-18	1088	1088	3014468	0.0004
24	Sep-18	672	672	3014468	0.0002
25	Sep-18	1678	1678	3014468	0.0006
26	Sep-18	2204	2204	3014468	0.0007
27	Sep-18	1769	1769	3014468	0.0006
28	Sep-18	991	991	3014468	0.0003
29	Sep-18	1539	1539	3014468	0.0005
30	Sep-18	588	588	3014468	0.0002
31	Sep-18	5943	5943	3014468	0.0020
32	Sep-18	2260	2260	3014468	0.0007
33	Sep-18	2693	2693	3014468	0.0009
34	Sep-18	1497	1497	3014468	0.0005
35	Sep-18	3433	3433	3014468	0.0011
36	Sep-18	1871	1871	3014468	0.0006
37	Sep-18	2823	2823	3014468	0.0009
38	Sep-18	1633	1633	3014468	0.0005
39	Sep-18	3433	3433	3014468	0.0011
40	Sep-18	1843	1843	3014468	0.0006
41	Sep-18	4227	4227	3014468	0.0014
42	Sep-18	5294	5294	3014468	0.0018
43	Sep-18	1402	1402	3014468	0.0005
44	Sep-18	2345	2345	3014468	0.0008

Sr.No.	Month	Ni = Number of consumers who experienced a sustained interruption on ith feeder	Sum of consumers of i feeders which had experienced interruptions = Sum Ni	Nt = Total number of consumers of the distribution Licensees area	SAIFI = (4) / (5) (Events)
45	Sep-18	1818	1818	3014468	0.0006
46	Sep-18	5151	5151	3014468	0.0017
47	Sep-18	4862	4862	3014468	0.0016
48	Sep-18	1457	1457	3014468	0.0005
49	Sep-18	4952	4952	3014468	0.0016
50	Sep-18	3007	3007	3014468	0.0010
51	Sep-18	2393	2393	3014468	0.0008
52	Sep-18	3293	3293	3014468	0.0011
53	Sep-18	6193	6193	3014468	0.0021
54	Sep-18	7508	7508	3014468	0.0025
55	Sep-18	3940	3940	3014468	0.0013
56	Sep-18	5451	5451	3014468	0.0018
57	Sep-18	8262	8262	3014468	0.0027
58	Sep-18	5375	5375	3014468	0.0018
59	Sep-18	6935	6935	3014468	0.0023
60	Sep-18	5084	5084	3014468	0.0017
61	Sep-18	4613	4613	3014468	0.0015
62	Sep-18	8445	8445	3014468	0.0028
63	Sep-18	6047	6047	3014468	0.0020
64	Sep-18	1245	1245	3014468	0.0004
65	Sep-18	3548	3548	3014468	0.0012
66	Sep-18	3	3	3014468	0.0000
67	Sep-18	357	357	3014468	0.0001
68	Sep-18	1456	1456	3014468	0.0005
69	Sep-18	1540	1540	3014468	0.0005
70	Sep-18	4171	4171	3014468	0.0014
71	Sep-18	1675	1675	3014468	0.0006
72	Sep-18	2614	2614	3014468	0.0009
73	Sep-18	4971	4971	3014468	0.0016
74	Sep-18	403	403	3014468	0.0001
75	Sep-18	4047	4047	3014468	0.0013
76	Sep-18	1013	1013	3014468	0.0003
77	Sep-18	1169	1169	3014468	0.0004
78	Sep-18	26	26	3014468	0.0000
79	Sep-18	29	29	3014468	0.0000
80	Sep-18	524	524	3014468	0.0002
81	Sep-18	990	990	3014468	0.0003
82	Sep-18	1897	1897	3014468	0.0006
83	Sep-18	3907	3907	3014468	0.0013
84	Sep-18	4862	4862	3014468	0.0016
85	Sep-18	1	1	3014468	0.0000
86	Sep-18	5696	5696	3014468	0.0019
Total		205092	205092	3014468	0.0680

Remark :

1 Customer served by Rinfra are 3014468 nos.

2 Number of feeders are 1167 Nos.

**Annexure-IV**  
**Performance Report regarding Reliability Indices**

Formats for Quarterly returns to be submitted to the Commission by the Distribution Licensee  
(3) Customer Average Interruption Duration Index (CAIDI)

Name of Distribution Licensee: Adani Electricity Mumbai Limited  
Period: July 2018 to Sept-2018

Sr.No.	Month	SAIDI	SAIFI	SAIDI/SAIFI (CAIDI in Minutes)
(1)	(2)	(3)	(4)	(5)
1	Jul-18	0.0000	0.0000	21
2	Jul-18	0.0002	0.0000	20
3	Jul-18	0.0004	0.0001	6.2
4	Jul-18	0.0005	0.0001	10
5	Jul-18	0.0012	0.0001	13.5
6	Jul-18	0.0014	0.0001	20
7	Jul-18	0.0017	0.0001	18
8	Jul-18	0.0020	0.0001	15
9	Jul-18	0.0028	0.0001	32.74
10	Jul-18	0.0030	0.0001	21
11	Jul-18	0.0030	0.0001	23.87
12	Jul-18	0.0037	0.0001	28.44
13	Jul-18	0.0051	0.0003	17
14	Jul-18	0.0052	0.0005	10.27
15	Jul-18	0.0055	0.0002	28.03
16	Jul-18	0.0060	0.0003	17.32
17	Jul-18	0.0062	0.0001	41.69
18	Jul-18	0.0069	0.0004	15.93
19	Jul-18	0.0071	0.0004	20
20	Jul-18	0.0072	0.0004	16.7
21	Jul-18	0.0073	0.0003	21.22
22	Jul-18	0.0074	0.0012	6
23	Jul-18	0.0079	0.0004	18
24	Jul-18	0.0084	0.0009	8.8
25	Jul-18	0.0084	0.0004	20
26	Jul-18	0.0084	0.0002	43.29
27	Jul-18	0.0087	0.0005	18.27
28	Jul-18	0.0093	0.0003	37
29	Jul-18	0.0094	0.0004	22.42
30	Jul-18	0.0094	0.0003	33
31	Jul-18	0.0096	0.0004	24
32	Jul-18	0.0100	0.0003	39.02
33	Jul-18	0.0107	0.0006	19.3
34	Jul-18	0.0109	0.0003	40.99
35	Jul-18	0.0114	0.0007	16.77
36	Jul-18	0.0118	0.0005	25.88
37	Jul-18	0.0147	0.0007	20
38	Jul-18	0.0149	0.0007	21.62
39	Jul-18	0.0158	0.0007	22
40	Jul-18	0.0160	0.0005	34.87
41	Jul-18	0.0174	0.0005	35.06
42	Jul-18	0.0184	0.0010	18.06
43	Jul-18	0.0207	0.0006	35.3
44	Jul-18	0.0215	0.0010	22
45	Jul-18	0.0225	0.0007	34.05
46	Jul-18	0.0235	0.0010	23.75
47	Jul-18	0.0256	0.0007	36.09
48	Jul-18	0.0328	0.0018	18.4
49	Jul-18	0.0378	0.0011	34.89
50	Jul-18	0.0379	0.0018	21.26

Sr.No.	Month	SAIDI	SAIFI	SAIDI/SAIFI (CAIDI in Minutes)
51	Jul-18	0.0398	0.0019	21.39
52	Jul-18	0.0437	0.0017	26.16
53	Jul-18	0.0471	0.0006	74.8
54	Jul-18	0.0498	0.0020	25.05
55	Jul-18	0.0510	0.0017	29.7
56	Jul-18	0.0525	0.0013	41.41
57	Jul-18	0.0529	0.0014	39
58	Jul-18	0.0634	0.0015	42.21
59	Jul-18	0.0781	0.0020	38.43
60	Jul-18	0.0853	0.0028	31
61	Jul-18	0.1031	0.0026	39.93
62	Jul-18	0.1935	0.0077	25.12
63	Jul-18	0.0005	0.0000	18
64	Jul-18	0.0006	0.0000	52.42
65	Jul-18	0.0083	0.0001	59.51
66	Jul-18	0.0090	0.0005	18.62
67	Jul-18	0.0117	0.0009	12.69
68	Jul-18	0.0147	0.0004	40.65
69	Jul-18	0.0167	0.0002	103.2
70	Jul-18	0.0247	0.0004	61.91
71	Jul-18	0.0514	0.0021	24.16
72	Jul-18	0.0514	0.0015	34.36
73	Jul-18	0.0737	0.0010	76.31
74	Jul-18	0.0123	0.0005	24.24
75	Jul-18	0.0211	0.0021	10.28
76	Jul-18	0.0545	0.0016	35.07
77	Jul-18	0.0743	0.0015	49
78	Jul-18	0.0028	0.0001	29
79	Jul-18	0.0065	0.0009	7
80	Jul-18	0.0150	0.0006	25.77
81	Jul-18	0.0153	0.0017	9
82	Jul-18	0.0365	0.0015	24
83	Jul-18	0.0458	0.0032	14.18
Total		1.94	0.07	27.06

Remark :

- 1 Customer served by Rinfra are 3013966 nos.
- 2 Number of feeders are 1164 Nos.

**Annexure-IV**  
**Performance Report regarding Reliability Indices**

**Formats for Quarterly returns to be submitted to the Commission by the Distribution Licensee**  
**(3) Customer Average Interruption Duration Index (CAIDI)**

Sr.No.	Month	SAIDI	SAIFI	SAIDI/SAIFI (CAIDI in Minutes)
(1)	(2)	(3)	(4)	(5)
1	Aug-18	0.0004	0.0000	15.4
2	Aug-18	0.0013	0.0001	14.88
3	Aug-18	0.0013	0.0001	22
4	Aug-18	0.0028	0.0001	36.53
5	Aug-18	0.0035	0.0002	18
6	Aug-18	0.0042	0.0002	27.01
7	Aug-18	0.0055	0.0004	13.03
8	Aug-18	0.0058	0.0003	20
9	Aug-18	0.0094	0.0007	13
10	Aug-18	0.0100	0.0006	15.92
11	Aug-18	0.0110	0.0003	43.25
12	Aug-18	0.0120	0.0007	16.18
13	Aug-18	0.0148	0.0005	27
14	Aug-18	0.0167	0.0007	23
15	Aug-18	0.0178	0.0006	29.5
16	Aug-18	0.0180	0.0008	22.95
17	Aug-18	0.0181	0.0004	50.14
18	Aug-18	0.0183	0.0008	23
19	Aug-18	0.0203	0.0007	28
20	Aug-18	0.0222	0.0020	11
21	Aug-18	0.0226	0.0009	23.83
22	Aug-18	0.0230	0.0007	35
23	Aug-18	0.0251	0.0014	18
24	Aug-18	0.0254	0.0007	35
25	Aug-18	0.0307	0.0009	34
26	Aug-18	0.0309	0.0008	36.66
27	Aug-18	0.0328	0.0012	27.22
28	Aug-18	0.0379	0.0010	37.48
29	Aug-18	0.0391	0.0013	29.29
30	Aug-18	0.0448	0.0027	16.62
31	Aug-18	0.0618	0.0103	6
32	Aug-18	0.0863	0.0021	40.51
33	Aug-18	0.1076	0.0007	146
34	Aug-18	0.1189	0.0039	30.3
35	Aug-18	0.1867	0.0024	76.78
36	Aug-18	0.0018	0.0000	231
37	Aug-18	0.0220	0.0005	46.85
38	Aug-18	0.0232	0.0014	16.32
39	Aug-18	0.0521	0.0018	28.8
40	Aug-18	0.0553	0.0010	55.27
41	Aug-18	0.0643	0.0008	76.38
42	Aug-18	0.0001	0.0000	46.8
43	Aug-18	0.0061	0.0003	23.56
44	Aug-18	0.0791	0.0026	30.58
45	Aug-18	0.0011	0.0002	7
46	Aug-18	0.0018	0.0002	10
47	Aug-18	0.0032	0.0002	18
48	Aug-18	0.0053	0.0005	10
49	Aug-18	0.0058	0.0007	8
50	Aug-18	0.0076	0.0008	9

Sr.No.	Month	SAIDI	SAIFI	SAIDI/SAIFI (CAIDI in Minutes)
51	Aug-18	0.0163	0.0009	17.15
Total		1.43	0.05	26.81

Remark :

- 1 Customer served by Rinfra are 3015065 nos.
- 2 Number of feeders are 1167 Nos.

**Annexure-IV**  
**Performance Report regarding Reliability Indices**

**Formats for Quarterly returns to be submitted to the Commission by the Distribution Licensee**  
**(3) Customer Average Interruption Duration Index (CAIDI)**

Sr.No.	Month	SAIDI	SAIFI	SAIDI/SAIFI (CAIDI in Minutes)
(1)	(2)	(3)	(4)	(5)
1	Sep-18	0.0000	0.0000	24
2	Sep-18	0.0000	0.0000	30.45
3	Sep-18	0.0002	0.0000	24.22
4	Sep-18	0.0002	0.0000	34
5	Sep-18	0.0003	0.0000	24
6	Sep-18	0.0009	0.0001	7.87
7	Sep-18	0.0018	0.0001	21
8	Sep-18	0.0018	0.0001	20
9	Sep-18	0.0027	0.0002	15
10	Sep-18	0.0036	0.0002	15
11	Sep-18	0.0037	0.0001	32
12	Sep-18	0.0038	0.0002	17.04
13	Sep-18	0.0042	0.0002	21.88
14	Sep-18	0.0042	0.0002	19
15	Sep-18	0.0046	0.0002	21
16	Sep-18	0.0048	0.0002	20
17	Sep-18	0.0049	0.0002	22
18	Sep-18	0.0051	0.0004	13.55
19	Sep-18	0.0061	0.0003	20
20	Sep-18	0.0064	0.0003	19.87
21	Sep-18	0.0072	0.0004	19
22	Sep-18	0.0073	0.0007	9.86
23	Sep-18	0.0073	0.0004	20.34
24	Sep-18	0.0074	0.0002	33
25	Sep-18	0.0083	0.0006	15
26	Sep-18	0.0084	0.0007	11.45
27	Sep-18	0.0090	0.0006	15.3
28	Sep-18	0.0100	0.0003	30.44
29	Sep-18	0.0112	0.0005	21.92
30	Sep-18	0.0115	0.0002	58.98
31	Sep-18	0.0118	0.0020	6
32	Sep-18	0.0120	0.0007	16
33	Sep-18	0.0142	0.0009	15.94
34	Sep-18	0.0144	0.0005	28.91
35	Sep-18	0.0148	0.0011	13
36	Sep-18	0.0171	0.0006	27.56
37	Sep-18	0.0175	0.0009	18.64
38	Sep-18	0.0175	0.0005	32.24
39	Sep-18	0.0194	0.0011	17
40	Sep-18	0.0214	0.0006	35.01
41	Sep-18	0.0239	0.0014	17.02
42	Sep-18	0.0240	0.0018	13.66
43	Sep-18	0.0264	0.0005	56.78
44	Sep-18	0.0280	0.0008	36.02
45	Sep-18	0.0308	0.0006	51
46	Sep-18	0.0308	0.0017	18
47	Sep-18	0.0324	0.0016	20.09
48	Sep-18	0.0333	0.0005	68.84
49	Sep-18	0.0334	0.0016	20.31
50	Sep-18	0.0355	0.0010	35.59



Sr.No.	Month	SAIDI	SAIFI	SAIDI/SAIFI (CAIDI in Minutes)
51	Sep-18	0.0374	0.0008	47.17
52	Sep-18	0.0408	0.0011	37.34
53	Sep-18	0.0436	0.0021	21.22
54	Sep-18	0.0491	0.0025	19.72
55	Sep-18	0.0536	0.0013	41
56	Sep-18	0.0543	0.0018	30.01
57	Sep-18	0.0545	0.0027	19.87
58	Sep-18	0.0609	0.0018	34.13
59	Sep-18	0.0620	0.0023	26.96
60	Sep-18	0.0646	0.0017	38.31
61	Sep-18	0.0673	0.0015	43.98
62	Sep-18	0.0699	0.0028	24.96
63	Sep-18	0.0743	0.0020	37.03
64	Sep-18	0.2281	0.0004	552.18
65	Sep-18	0.2937	0.0012	249.52
66	Sep-18	0.0001	0.0000	53
67	Sep-18	0.0015	0.0001	13
68	Sep-18	0.0069	0.0005	14.33
69	Sep-18	0.0174	0.0005	33.99
70	Sep-18	0.0181	0.0014	13.1
71	Sep-18	0.0204	0.0006	36.65
72	Sep-18	0.0277	0.0009	32
73	Sep-18	0.0289	0.0016	17.53
74	Sep-18	0.0314	0.0001	235.2
75	Sep-18	0.0527	0.0013	39.28
76	Sep-18	0.0679	0.0003	202
77	Sep-18	0.2160	0.0004	557
78	Sep-18	0.0001	0.0000	6.62
79	Sep-18	0.0002	0.0000	18
80	Sep-18	0.0061	0.0002	35
81	Sep-18	0.0090	0.0003	27.33
82	Sep-18	0.0113	0.0006	18
83	Sep-18	0.0508	0.0013	39.23
84	Sep-18	0.0583	0.0016	36.14
85	Sep-18	0.0000	0.0000	10.8
86	Sep-18	0.2066	0.0019	109.35
Total		2.6908	0.0680	39.55

Remark :

- 1 Customer served by Rinfrac are 3014468 nos.
- 2 Number of feeders are 1167 Nos.