

TENDER NUMBER – AMIL/2021-22/04

NAME OF WORK – Proposed permanent boundary wall at Village-Usar and Transition Station at Village-Mandvi

DATE AND TIME OF PRE-BID MEETING – 11.11.2021 @ 11.30 HRS

REPLIES TO TECHNICAL QUERIES RAISED DURING PRE-BID MEETING

SR. NO.	QUERY RAISED BY VENDOR	REPLY BY AEML
1.	Clarity required on disposal of Excavated earth and Debris generated out of pile breaking.	Disposal of additional/surplus earth and debris generated during pile breaking shall be filled within low lying portion of the plot with proper levelling and compaction as per directions of the engineer in charge. This will be in the scope of vendor and shall not be paid separately.
2.	Shall AEML allow establishment of labour colony within the plot.	The vendors are required to submit following data along with their tender submission. (1) Number of labour expected to be accommodated at site (2) Deployment Schedule-Phase wise/Activity wise (3) Area requirement (in m ²) for labour colony Based on this, discussions shall be done with individual vendor during Technical Evaluation Stage.
3.	Whether piling can be done with rotary drilling or conventional tripod method.	Vendor to select suitable method to ensure that work is completed within scheduled time period.
4.	Whether payment for pile shall be done up to NGL or up to cut off level	The payment for pile shall be done up to NGL.
5.	Please give clarity on 2 different types of gate	There will be 3 Gates at Kudus. One main gate shall be 6 m width. Other 2 gates of 4m width shall be for gut no.9 & 24. 1 No. 6m wide main entrance gate at transition station.
6.	Whether RCC Columns portion can be separated from Item No. 14	The item No. 14 shall be operated for fabrication & erection of 4 structural steel gates and steel for the concertina coil supporting as per specifications, drawings and directions of EIC. The RCC columns for steel gate are included in this rate and shall not be paid separately.
7.	Shall Vizag Steel be allowed for reinforcement	Yes. If it is a primary steel manufacturer.
8.	Please share bore log data for Kudus Plot	Bore Log is uploaded on the website for information.