

Pre-Bid Meeting - 33-22/11.3 KV 16/20 MVA NEPT NIT AEML/MDB/2020-21/40

Technical Query

Participants:
1. M/s Schneider Electric - Mr. Abhishek Jog
 Mr. Puneet Bhatia
 Mr. Raturaj Gadekar
 Mr. Vikrant Savarkar
 Mr. Vivek
2. M/s Cargill - Mr. Deepak Loya
3. M/s Om Technical Solutions - Mr. Dheerendra
4. M/s QRE : Mr. Balaji
5. M/s ABB : Mr. Prashant Ranpura
 Mr. Sandesh Pol
6. M/S Energypac : Mr. Sambodhi Goswami
 Mr. Safayet
7. M/S AEML : Mr. Damodar Sahasrabuddhe, Mr. Ashish Nema, Mr. Abhijit Dandekar, Mrs. Meghna Bothe

MOM: 13.05.2020

1. AEML explained the scope of supply, Technical Specification requirements to Bidders.
2. During pre-bid meeting, Bidders raised queries, response of which is attached herewith.
3. In case Bidders wish to send additional Technical queries, they can send mails to CES Dept. with a copy to CPG.

Sr. no.	Document	Clause no /Sr.No of BOQ	Description	Query	Query raised by	AEMLRemark	Inclusion in Corrigendum
1	Technical Specification SP-CES-EL-OPTR-R06	GTP 10.1 & 10.2	Temperature Rise Oil - 50 Deg (Easter Oil) Temperature Rise Winding - 55 Deg (Easter Oil)	Temperature rise for last PT supply with easter Oil - 60/65 Deg C	M/s Schneider	Temperature Rise Oil - 60 Deg (Easter Oil) Temperature Rise Winding - 65 Deg (Easter Oil)	Yes
2	Technical Specification SP-CES-EL-OPTR-R06	Clause 14.34	OLTC	Oil Type or Vacuum Type	M/s Schneider	Internal Intank Vacuum Type OLTC. Chinese make is acceptable	Yes
3	Technical Specification SP-CES-EL-OPTR-R06	5.6.4.1	Radiator	Material - Pressed Steel/ Stainless Steel	M/s Schneider	Pressed Steel	Yes
4			Delivery Requirement	Delivery Requirement	M/s ABB	Dec-20	
5			Additional Documents to be submitted along with Tender Documents		AEML	Bidders to submit following Documents : 1. PT, NIFPS and OIL GTP in excel sheet 2. Deviation sheet referring to specification clause no.-in excel sheet 3. Thermal ability to withstand Short Circuit Calculations 4. Temperature rise calculation 5. Core Wt & No laod loss calculation 6. Resistance & Load Loss calculation	Yes
6			commercial query	Submission of EMD and tender fees		Due to Lockdown situation ,EMD and DD be submitted on or before 30-June-20.In case EMD/ DD is not submitted by mentioned date ,your submitted bid will be considered as invalid.All bidders are required to submit undertaking letter mentioning EMD/DD shall be submitted by 30-June-20 while submitting bid	