

**Pre-Bid Meeting - Supply of assorted sizes of HT cables AEML/MDB/2021-22/08**

Technical Query				
<b>Participants:</b> 1. Kaushik Waghela - KEC 2. Manoj Verma - paramount Cables 3. NL Parab - KEI 4. Sachin Mene - KEI 5. Prashant Tiwari -Torrent 6. A N Pathak - Gemscab 7. Ashish sawant - Gupta power 8. Anshuman Nayak - Polycab		<b>MOM: 17.02.2021</b>  1. During pre-bid meeting, Bidders raised queries, response of which is attached herewith. 2. In case Bidders wish to send additional Technical queries, they can send mails to CES Dept. with a copy to CPG.		
Sr. no.	Query	Query Raised By	Description	AEML Remark
1	Armour	Prashant Tiwari - Torrent	Specify armour type for cable	GI Flat Strip armour for 3C cables and Al round wire armour for 1C cables
2	Outer Sheath	Prashant Tiwari - Torrent	Outer Sheath - PVC or HDPE	For material codes 2100241758 & 2100241759 outer sheath shall be HDPE ST7 for all other cables outer sheath shall be PVC ST2
3	Outer sheath properties	AN Pathak - Gemscab	FRLSH properties for outer sheth required?	Not required
4	Insulation material	AN Pathak - Gemscab	Can only XLPE as insulation accepted instead of water tree retardant properties (TR -XLPE)?	Extruded XLPE Insulation, with water-tree retardant (WTR) property is accepted only.
5	Conductor wires	Anshuman - Polycab	Do AL ingots from AEML approved vendors instead AL rods as raw material for conductor is accepted.	Accepted
6	Commercial Query		IEEMA Base for Variable Prices	Bidders has to consider IEEMAs Circular issued in Feb 2021 as Base for Variable Prices