

Pre-Bid Clarifications - Supply of assorted sizes of LT cables AEML/MDB/2021-22/O2

Technical Query

<p>Participants:</p> <ol style="list-style-type: none"> 1. Kaushik Waghela - KEC 2. Manoj Verma - paramount Cables 3. NL Parab - KEI 4. Sachin Mene - KEI 5. Pankaj Tiwari - Gemscab 6. Prakash lakhkar - Ravin 7. Siddharth - Shree Vinayak Plasto Chem 8. Rajendra Lad - Apar 9. Rakesh Remma 10. Sunil Jindal 11. Satish 12. Vinod Kumar 13. Pradeep 14. A N Pathak - Gemscab <p>M/S Adani Electricity - Mr. Ashish Nema, Mr. Abhijit Dandekar, Mr. Devendra Mahajan</p>	<p>MOM: 13.01.2021</p> <ol style="list-style-type: none"> 1. During pre-bid meeting, Bidders raised queries, response of which is attached herewith. 2. In case Bidders wish to send additional Technical queries, they can send mails to CES Dept. with a copy to CPG.
---	---

Sr. no.	Query	Query Raised By	Description	AEML Remark
1	Water Swellable Tape	N L parab/ Sachin Mene - KEI	Consider thickness of water swelleble approx. 0.3 mm instead of 0.3mm min,	Thickness of water swelleble tape will be 0.3 mm Minimum.
2	Qualifying Criterian	Siddharth - Shree Vinayak Plasto	Relaxation in 200 Cr turnover criterian	Qualifying criterian shall be strictly as per Tender Document. Relaxation will not be considered.
3	Armour	Gupta Power/Gemscab	Specification Cl.9.1(b)- Zinc coating of armour 210 gms/sq.m whereas, as per IS 3975 it is 110 gms/sq.m	Mass of zinc coating over armour shall be min. 110 gms/sq.m as per IS 3975.
4	Commercial Terms	Apar/KEC	Requested for Variable price based on IEEMA	Vendor has to provide prices for both options FIRM prices & Variable Prices based on Latest IEEMA. AEML will decide suitable Option at the time of Finalization of Order.
5	Commercial Terms	Apar/KEC	Requested for relaxation in Credit period.	Vendor has to retain AEML standard credit Payment Terms. Incase vendor has taken deviation on Credit period Financial Loading will be done on vendor quoted prices at the time of commercial Evaluations.