

Addendum:-

1.1 NIT/Bid Document No.: AEML/MDB/2019-20/25.

Package Name: Supply of assorted sizes of LT feeder pillars, feeder Panels and metering panels

Earlier clause:

1.5 Bid details

- a. Earnest Money Deposit (EMD)/ Bid Security: Rs. 17.87 Lac/- (refundable without interest) (EMD, only in the form of D.D. / Banker's Cheque / Bank Guarantee, to be valid up to 180 days from the date of techno-commercial bid opening). All the suppliers will have to pay EMD before bid end date, without which, their price bid shall not Be opened. No interest will be paid on such deposits.

Revised Clause:

Should read as:-

- b. Earnest Money Deposit (EMD)/ Bid Security: Rs. **5.00 Lac/-** (refundable without interest) (EMD, only in the form of D.D. / Banker's Cheque / Bank Guarantee, to be valid up to 180 days from the date of techno-commercial bid opening). All the suppliers will have to pay EMD before bid end date, without which, their price bid shall not Be opened. No interest will be paid on such deposits.

Note: This change in EMD amount shall be applicable strictly for this tender only

MOM of pre-bid held on 01/07/2019 regarding open tender for supply of feeder pillars and panels Ref. no. AEML/MDB/2019-20/25

Document	Clause No.	Query/ Point of discussion	AEML remark
Specifications of LT Feeder Without ACB	Drawings attached	Structural foundation	Structural foundation shall be provided with each pillar as per technical specifications.
	9.11	Provision of polycarbonate sheet	The same shall be as per clause no. 9.11 of technical specifications.
	5.26	Scope of hardware	Incoming and outgoing cable hardware in manufacturer's scope. The same shall be as per specifications.
	NA	Scope of fuse	Provision of fuse is not in scope of manufacturer.
	NA	Lock make alternatives	The same shall be as per specifications.
LT feeder pillar panel With ACB	5.24	Fuse strip	Pillars shall be with fuse base arrangement only, fuse strips are not to be considered.
	6.1	Temperature monitoring relays and sensor scope	The same is in manufacturer's scope only. Alternate approved make of temperature monitoring relay shall be Masibus 8208.
	NA	Please provide part no/CAT no of ACB.	The same shall be per specifications.
	NA	Rear doors of ACB Panels are with Dhirak/Emka locks or with simple locks.	The same shall be as per specifications
CT metering panel	5.5	CT provision scope	Provision of CTs is in manufacturer's scope only.
	5.8	Confirmation of Busbar size	Busbar sizes and material shall be as per drawings in specifications.
	14.B	Scope of TTB and make	Provision of TTB is in manufacturer's scope only. Approved Makes shall be as per specifications.
	NA	Dimensions of panel	The dimensions shall be as per drawings attached with specifications. However, bidder has to prepare and submit detailed drawings for approval in the event of order
	NA	Panel is extensible type or not	Panel is not extensible.

MOM of pre-bid held on 01/07/2019 regarding open tender for supply of feeder pillars and panels Ref. no. AEML/MDB/2019-20/25

Document	Clause No.	Query/ Point of discussion	AEML remark
Stand alone panel	Page 14	Confirmation on switch type	The switch is SDF only and not MCCB.