

Minutes of Virtual Pre-bid Meeting held between M/s Adani Electricity Mumbai Ltd and bidders on 18.02.2021 for GI Earthing Material Open Tender

Bidders Present – M/s Parth Metals, M/s Crystal Enterprises, M/s Grindwell Ind, M/s Dreamers World, M/s Remedies Earthing Systems, M/s U-Protec Earthing

NIT No: AEML/MDB/2021-22/10

Members Present:

AEML

1. Yogesh B. Deshmukh - CES
2. Rajendrasing Girase - CES
3. Ketan Bhagat – CPG
4. Mubarak Batwale – CPG

Bidders

1. Parth Bhula
2. Sudeep Mane
3. Yogendrasing Girase
4. Ashish Patil
5. Anup Tiwari
6. Divya Singh
7. U-Protec Earthing

Discussion on the following points was done against various bidder's queries in pre-bid meeting. Clarifications to the queries are made as under-

1. All hardware shall be 8.8 HTS and Hot Dip galvanized as per tender technical specification (M/s Crystal Ent)
2. Tender quantity may be split amongst successful bidders (M/s Crystal Ent)
3. BG shall be preferred over retention deduction against contract value. (M/s Crystal Ent)
4. CPBG process explained as per request of Ms. Divya Singh, Remedies Earthing Systems
5. For 4 Ft electrode, clamp welded shall be of 40X3 mm strip. (Ms. Divya Singh, Remedies Earthing Systems)
6. ISI marks on pipes shall be verified as per availability according to cut length (U-Protec Earthing P Ltd)
7. Part bidding may be accepted against tender BoQ. (U-Protec Earthing P Ltd)
8. No concessions for MSME registered bidders for EMD. (U-Protec Earthing P Ltd)
9. Test certificates for raw material (pipe and strips) and galvanisation process shall be submitted for each lot offered. (U-Protec Earthing P Ltd)

10. Lot-wise inspection call shall be submitted for physical inspection at bidder's work and also upon receipt of material at AEML store end.
11. Zinc coating thickness for HDG pipes and strips shall be 85 Micron inside and outside
12. 1 No. hole shall be provided on tip of cone of earthing spike for 2.5 and 4 Ft spikes
13. Bidders need to upload all supporting documents against tender PQR along with signed and stamped copy of Pre-bid MoM, Technical Specification, NIT document before due date.