

Corrigendum : 5

Tender NIT NO: AEML/MDB/2021-22/62

Tender Description: Procurement of 200 A Whole Current Smart Composite Meters

All Bidders kindly note below mentioned changes in the Technical Specifications & BOQ.

AEML intends to buy a conventional DMLS Composite meter complying IS 13779 and IS 15959 part 1 and retrofit wired serial port for communication. Revised Specifications & BOQ is attached for your reference.