

Technical Query

Participants: 1. Hex 2. Braco 3. Pioneer 4. AEML- Ashweni Jain, Tanu Srivastava	MOM: 1. AEML explained the scope of supply, Technical Specification requirements to Bidders. 2. During pre-bid meeting, Bidders raised queries, response of which is attached herewith. 3. In case Bidders wish to send additional Technical queries, they can send mails to CES Dept. with a copy to CPG.
--	--

Sr. no.	Document	Clause no /Sr.No of BOQ	Clause	Description	Query	Query raised by	AEMLRemark	Inclusion in Corrigendum
1	AEML spec SP-CES-EL-MI-BGLAD-ROO	CI 5.3.0	Earthing tag	To ensure proper earthing, the cable glands shall be fitted with an earthing tag	-	-	1. Earth tag on glands shall be provided with ring type tinned copper lug suitable for 4 sqmm Cu wire for all sizes of glands 2. Earth tag shall be provided separately, not connected with the gland	Yes
2	AEML spec SP-CES-EL-MI-BGLAD-ROO			Screws on both the side of glands			The screws and bolts shall be hot dip galvanised	Yes
3	AEML spec SP-CES-EL-MI-BGLAD-ROO	6.1.0	Testing and inspection details				Third party metal analysis test of each component of each size of gland is needed to be carried out by vendor during the event of order	Yes
4	AEML spec SP-CES-EL-MI-BGLAD-ROO	8.0.0	Packing details				AEML, vendor name, vendor ID shall be provided on glands with laser scibbing	Yes
5							Sample approval before mass production on PO placement	Yes
6					The thread type in double compression type	M/s Braco	ET type	Yes