

Minutes of Virtual M S Teams Meeting between M/s AEML and DITC of Substation Equipment Bidders for Prebid Meeting against NIT No- AEML/MDB/2021-22/46 on 23.07.2021

Member Present:

AEML	Bidders
1. Umesh Huddar – HT Construction	1. Shrishail V K – Shree Electricals
2. Yogesh B. Deshmukh - CES	2. L. B. Singh -Akanksha Infracom P Ltd
3. Arbind Rai -CPG	3. Rajeev Pillai
4. Nikhil Gupta-CPG	4. R. V. Kakade
5. Mahesh Doiphode - Budgeting	5. V. E. Gounder
	6. Pramod - Shree Electricals
	7. Guntant Padharia
	8. C. P. Yadav
	9. Vikas Infra
	10. Amol Kulkarni -Core
	11. Vivek -G V Electricals
	12. ServiceOne FM
	13. Skylark Enterprises
	14. Gandhekar Electrical Pvt Ltd
	15. Rinkal Ranpariya
	16. Veer
	17. Sujay
	18. Wasim
	19. Kumar Ramakrishnan
	20. M. Gopinathan

Following points were discussed against various bidder's queries in pre-bid meeting. Clarifications to the queries are made as under-

1. PQR – Only stipulated work experience is essential or rest other parameters shall be considered (Mr Amit-Core)

AEML Reply – Eligibility shall be as per bid PQR. In case of any specific point query, pl. email on contacts mentioned in bid document

2. Reverse auction applicability (Mr Amit-Core)

AEML Reply – There shall be reverse auction.

3. In some of the jobs there is excess manual shifting work (Mr Vivek – G V Electricals)

AEML Reply – Overall cases involving manual shifting are very less hence, to be considered as per tender BoQ

4. Core cutting -slab thickness not furnished in BoQ (Mr Vivek – G V Electrical)
AEML Reply – Approx. slab thickness shall be 450 mm.
5. Scope of Electrical approval and approximate Substation count for services (Mr Shrishail V K – Shree Electricals)
AEML Reply – In AEML scope / about 230 Nos.
6. OEM engineer requirement for testing and commissioning job and continuous work front availability (Mr Shrishail V K – Shree Electricals)
AEML Reply – To be considered in bidder's scope / work flow shall be continuous.
7. EMD and tender fee. EMD to be in the form of BG (Mr Pramod – Shree Electricals/ Mr Amit-Core)
AEML Reply – EMD – 2 lacs, tender fee is nil. EMD can be accepted in the form of BG. EMD format shall be uploaded. No tender fee shall be applicable.
8. Offer submission with GST (Mr Pramod – Shree Electricals / Gandhekar Electrical Pvt Ltd)
AEML Reply – Offers shall be submitted as per BoQ format i.e. basic prices and at the end total GST applicable to be considered
9. Site obstructions and improper access to proposed sites (Mr Shrishail V K – Shree Electricals)
AEML Reply – AEML shall arrange site visit before start of work for site access /readiness
10. Approximate period for PO allotment (Mr Shrishail V K – Shree Electricals)
AEML Reply – Within one and half month
11. Line-item no. 160 from BoQ mentions about services 2 nos. of transformer against single line item (Mr C P Yadav)
AEML Reply – For 2 transformer services, single line item shall be considered
12. Line-item no. 890 (Earthing Resistance Measurement) from BoQ mentions UoM as Job (Mr C P Yadav)
AEML Reply – UoM for line item 890 shall be Nos.

13. Line-item no. 160 from BoQ mentions Oil/Dry transformer installation and filtration not considered in scope (Mr Shrishail V K – Shree Electricals)
AEML Reply – Oil filtration not in bidder's scope of work.
14. Breaking of concrete – scope clarity required i.e. for road concrete or substation premises concrete considering special tools requirement (Gandhekar Electrical Pvt Ltd)
AEML Reply – breaking of concrete shall be applicable w.r.t substation premises and not for main roads
15. Minor concrete breaking to be covered in job (Mr Shrishail V K – Shree Electricals)
AEML Reply – It shall be covered in respective line item
16. Line-item no. 780 from BoQ (Excavation of cable trenches) – Scope of disposal of excess sand (Gandhekar Electrical Pvt Ltd)
17. AEML Reply – Disposal of excess sand as directed by Engineer-in charge shall be in bidder's scope
18. AEML clarifications -
 - i. LV ACB primary injection shall be considered in scope of work; Necessary valid calibrated test equipment shall be made available at site
 - ii. No hard copy shall be submitted for bid submissions
 - iii. Bidder to submit all necessary details about-
 - a. Skilled manpower – name, age qualification, experience
 - b. Unskilled manpower
 - c. Tools and tackles details with valid calibration report
 - d. Work experience /performance certificates of similar works
 - e. Other PQR supporting documents against each parameter
19. Due date for bid submission is 02nd Aug-2021 which shall not be extended in any case.