

### TYPE TEST REPORT SUMMARY

ITEM :									
VENDOR :									
Sr. No.	Type Tests stipulated as per Tender Spec/Standards	Applicable standard	Acceptance Norms as per IS / IEC & Specs	Tests conducted by the Mfr ( Yes/No)	Date of Tests Conducted	Name of the test Lab	Test Values as per report	Acceptance code ( Yes/No)	Remarks
1	Short time withstand current and peak withstand current ( Main & earthing circuit)								
2	Temperature rise test & Measurement of resistance of main circuit								
3	Internal arc test ( CB, BB & CC )								
4	Dielectric tests ( Power frequency voltage, Impulse )								
5	Partial Discharge								
6	Short time withstand current and peak withstand current , Short circuit current Making & breaking test, Single phase and double earth fault								
7	Tightness and pressure withstand test of gas filled compartment								
8	Operation & mechanical endurance (CB ,DS & ES)								
9	Electrical endurance (E2) - breaker								
10	Degree of protection								
11	Mechanical impact								
Note: Provide applicable TTR apart from above mentioned TT for 33 kV GIS panels and also provide TTR for all major equipments Numerical Relays, CT ,PT, Bushings and Termination Kit etc.									
Signed by Vendor		Signed by Client							